

DOCUMENT 00913

ADDENDUM NUMBER 3

Issued: September 29, 2010

**1315 Airport Boulevard Tenant Improvements
(Geothermal Heat Pump Retrofit)**

FROM: Sonoma County Water Agency
404 Aviation Boulevard
Santa Rosa, CA 95403-9019

TO: Prospective Bidders

This Addendum forms a part of and modifies the Project Manual dated August 2010. Bidder shall acknowledge receipt of this Addendum in the space provided in Document 00400 (Bid Form).

Addendum Number 3 consists of 3 pages (size 8 1/2" x 11") and 0 revised Drawings.

I. General Changes

A. No changes.

II. Changes to Prior Addenda

A. No changes.

III. Changes to Introductory Information and Bidding Requirements

A. No changes.

IV. Changes to Contracting Requirements

A. Add 05500 (Notice to Proceed), attached, after Document 00520 (Agreement).

V. Changes to Conditions of the Contract

A. No changes.

VI. Changes to Specifications

A. No changes.

VII. Changes to Drawings

A. Drawing No. M0.00:

1. On the Extended Range Water Source Heat Pump Schedule, HP-11, EER column, delete "7.9" and replace with "17.9."

VIII. Question(s)/Answer(s)

No questions received since issuance of Addendum Number 2.

END OF DOCUMENT

SONOMA COUNTY WATER AGENCY,
A Public Agency of the State of California

By : _____

Its: _____

[Notice to be sent in manner required by Contract Documents]

END OF DOCUMENT