

DOCUMENT 00913

ADDENDUM NUMBER 3

Issued: August 19, 2010

**1315 Airport Boulevard Tenant Improvements
(Geothermal Ground Loop)**

FROM: Sonoma County Water Agency
404 Aviation Blvd.
Santa Rosa, CA 95403-9019

TO: Prospective Bidders

The Sonoma County Water Agency received no Bids at the July 29, 2010 Bid Opening for the Project, and therefore is proceeding with a competitively negotiated contract, pursuant to Public Contract Code 22038(c), based on proposals in the form of bids. Prospective Bidders shall use the Bidding Documents issued with the Project Manual dated June 2010 to submit their price for the Work.

This Addendum forms a part of and modifies the Project Manual dated June 2010 and Addendum Number 2 dated July 20, 2010. Bidder shall acknowledge receipt of this Addendum in the space provided in Document 00400 (Bid Form).

Modified text is indicated as follows: Double-underline designates text to be inserted; ~~strikethrough~~ designates text to be deleted.

Addendum Number 3 consists of 2 pages (size 8 1/2" x 11") and 0 revised Drawings.

I. General Changes

- A. No changes.

II. Changes to Prior Addenda

- A. Under item VI (Changes to Specifications) delete item A and replace with the following:
 - 1. Section 15600 (Ground Heat Exchanger):
 - a. Delete Paragraph 1.4 A and replace with the following:
 - A. The ground loop pipe, fittings, and fusion joints shall be warranted by the manufacturer's warranty against defects in workmanship and materials for a minimum of 25 years.

III. Changes to Introductory Information and Bidding Requirements

- A. At all occurrences:
 - 1. Change Bid Opening date from July 29 to September 2.

IV. Changes to Contracting Requirements

A. No changes.

V. Changes to Conditions of the Contract

A. No changes.

VI. Changes to Specifications

A. See item A under Article II (Changes to Prior Addenda) above.

VII. Changes to Drawings

A. No changes.

VIII. Question(s)/Answer(s)

No questions received since issuance of Addendum Number 2.

END OF DOCUMENT