

DOCUMENT 00912

ADDENDUM NUMBER 2

Issued: January 4, 2011

**1315 Airport Boulevard Tenant Improvements
(Geothermal Heat Pump Retrofit)**

FROM: Sonoma County Water Agency
404 Aviation Blvd.
Santa Rosa, CA 95403-9019

TO: Prospective Bidders

This Addendum forms a part of and modifies the Project Manual dated December 2010. Bidder shall acknowledge receipt of this Addendum in the space provided in Document 00400 (Bid Form).

Modified text is indicated as follows: Double-underline designates text to be inserted; ~~strikethrough~~ designates text to be deleted.

Addendum Number 2 consists of 2 pages (size 8 1/2" x 11") and 0 revised Drawings.

I. General Changes

A. No changes.

II. Changes to Prior Addenda

A. No changes.

III. Changes to Introductory Information and Bidding Requirements

A. No changes.

IV. Changes to Contracting Requirements

A. No changes.

V. Changes to Conditions of the Contract

A. No changes.

VI. Changes to Specifications

A. Section 15815 (Ductwork and Accessories):

1. Delete Paragraph 2.11 D.2 and replace with the following:
2. Provide opposed blade dampers, in the duct behind the diffusers, to existing diffusers which do not have integral opposed blade dampers.

VII. Changes to Drawings

A. No changes.

VIII. Question(s)/Answer(s)

No questions received since issuance of Addendum Number 1.

END OF DOCUMENT