

DOCUMENT 00913

ADDENDUM NUMBER 4

Issued: November 6, 2009

Russian River CSD Treatment Plant Generator Replacement Project

FROM: Russian River County Sanitation District
PO Box 11628
Santa Rosa, CA 95406-1628

TO: Prospective Bidders

This Addendum forms a part of and modifies the Project Manual dated October, 2009. Bidder shall acknowledge receipt of this Addendum in the space provided in Document 00400 (Bid Form).

Modified text is indicated as follows: Single -underline designates text to be inserted; ~~striketrough~~ designates text to be deleted.

Addendum Number 4 consists of 2 pages (size 8 1/2" x 11"), including notes added to Drawing E-3.

I. General Changes

A. No changes

II. Changes to Prior Addenda

A. No changes

III. Changes to Introductory Information and Bidding Requirements

A. Document 00100, "Advertisement for Bids"

1. Paragraph 11: **Correct Error Message on paragraph reference.**

a. **BID SUBMISSION BID SUBMISSION.** Sealed Bids will be received at Owner's Office (see paragraph ~~Error! Reference source not found~~ 5) until 1:00 p.m., Thursday, November 12, 2009...

B. Document 00200 "Instructions to Bidders".

1. Paragraph 1: **Correct Error Message on paragraph reference**

a. **RECEIPT OF BIDS.** Sealed Bids will be received at Owner's Office (see paragraph ~~Error! Reference source not found~~ 5) of this Document 00913 and Document 00203 [Bid Submittal Vicinity Map] on Thursday, November 12, 2009...

IV. Changes to Contracting Requirements

A. No changes.

V. Changes to Conditions of the Contract

A. No changes.

VI. Changes to Drawings

A. Add Notes 9 and 10 to **Drawing No. E-3**. Notes should read as follows:

9. Bus flange with cabling to the ATS lugs for normal, load, and emergency is required. Cabling for each phase should be rated at 1600A. The ATS shall be top entry.

10. Bus flange with cabling to the generator circuit breaker lugs is required. Cabling for each phase should be rated at 1200A.

VII. Question(s)/Answer(s)

A. No questions received since issuance of Addendum Number 3.

END OF DOCUMENT