

DOCUMENT 00913

ADDENDUM NUMBER 3

Issued: July 30, 2012

**Santa Rosa Aqueduct Seismic Hazard Mitigation
(Rodgers Creek Fault Crossing)**

FROM: Sonoma County Water Agency
404 Aviation Blvd.
Santa Rosa, CA 95403-9019

TO: Prospective Bidders

This Addendum forms a part of and modifies the Project Manual dated June 2012, and Addendum Number 1 dated July 24, 2012. Bidder shall acknowledge receipt of this Addendum in the space provided in Document 00400 (Bid Form).

Modified text is indicated as follows: Double-underline designates text to be inserted; ~~strikethrough~~ designates text to be deleted.

Addendum Number 3 consists of 2 pages (size 8 1/2" x 11") and 0 revised Drawings.

I. General Changes

A. No changes.

II. Changes to Prior Addenda

A. Section 09900 (Paints and Protective Coatings):

1. Modify Paragraph 1.5 A.2 as follows:

2. Exterior Coating System Technical Requirements:

a. Exterior/Outside coating system (OCS) shall be ANSI/AWWA C222, ~~C210~~C213, or C205, as indicated.

III. Changes to Introductory Information and Bidding Requirements

A. No Changes.

IV. Changes to Contracting Requirements

A. No Changes.

V. Changes to Conditions of the Contract

A. No Changes.

VI. Changes to Specifications

A. Section 09900 (Paints and Protective Coatings):

1. Modify Paragraph 1.2 C as follows:

- C. ANSI/AWWA ~~C210~~C213 ~~Liquid Epoxy Coating Systems for the Interior and Exterior of Steel Water Pipelines~~
Fusion-Bonded Epoxy Coating for the Interior and Exterior of Steel Water Pipelines

2. Modify Paragraph 1.5 A.1.b. as follows:

- b. ICS shall meet ANSI/AWWA ~~C210~~C213. Alternatively ICS shall meet ANSI/AWWA C222.
-

VII. Changes to Drawings

A. No Changes

VIII. Question(s)/Answer(s)

Owner's responses to Bidder questions shall be for the purposes of interpretation and clarification of the Contract Documents only, and shall not be construed as changing, superseding, or contradicting any express term in the Contract Documents. If any Bidder believes that a response to a question warrants a change in any term in the Contract Documents, the Bidder shall so request the change be made in writing addressed to Owner and received no later than the latest date for submitting Bidder questions. In the absence of a change in any term of the Contract Documents, the express terms of the Contract Documents shall have precedence. Bidder questions are listed below verbatim.

A. Cal-Sierra Pipe, LLC

- Addendum 1 - Section 09900 - E-1-2-a states that C222, C210 or C205 should be used as indicated for the outside coating system. The piping schedule calls out fusion bond epoxy which is C214. Should C214 also be listed in the spec as an approved outside coating?

Owner's response: Answered in this Addendum above.

B. Apex Testing Laboratories, Inc.

- My name is Sarah and I'm with Apex Testing Labs. I have a couple of questions about the above referenced project regarding materials testing and special inspection. I was wondering whether we should bid for testing through the owner or through the general contractor. I would also like to know if an RFP/RFQ has been issued for testing yet. I would appreciate it if you replied to my email with any further updates regarding the project.

Owner's response: This is in the Bidding Documents.

END OF DOCUMENT